



Certificate of constancy of performance for products

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011.
(Construction Products Regulation or CPR)

Delivered by :

Notified Body : **AFNOR Certification**
Identification number : **0333**
Address : **11 rue Francis de Pressensé
FR - 93571 LA PLAINE SAINT-DENIS CEDEX**

Delivered to :

Company: **LIFE SAFETY DISTRIBUTION AG**
Address : **Trading as System Sensor Europe
Javastrasse 2
8604 Hegnau
Suisse**

Manufacturing site(s) : **Trieste - Italie**

Product : **Point heat detector using radio links - NRX-TDIFF**

Detailed description of product : Appendix

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard(s), below stated, under system 1 are applied and that the product fulfills the provisions described in annex ZA of the standard(s) below designated.

Fire detection and fire alarm systems

EN 54-5:2000 + A1:2002 - Heat detectors - Point detectors
EN 54-25:2008 + AC:2010 - Components using radio links

Certificate number : **0333-CPR-075494**

Certificate expiry date : **6 October 2021**

This certificate was first issued on 6 October 2016. Unless suspension or canceled, this certificate remains valid as long as the conditions laid down in the reference technical specifications or the manufacturing conditions in the factory or the factory production control or the product itself are not modified significantly.

Date of certificate delivery : **6 October 2016**



Franck LEBEUGLE
Managing Director of AFNOR Certification



Certificat

Certificate

Appendix to the certificate

Company : LIFE SAFETY DISTRIBUTION AG
Certificate number : 0333-CPR-075494
Manufacturing site(s) : Trieste - Italie
Date of certificate delivery : 6 October 2016

Product's description :

Identification of certified product(s) (Reference)	Product designation / Use	File number
NRX-TDIFF Brand : Notifier by Honeywell	Point heat detector using radio links Class : A1S	075.1036

This appendix cannot be submitted or reproduced without the document to which it is attached.

Franck LEBEUGLE
Managing Director of AFNOR Certification



005 - 2016/02 -