

# LPCB

## This is to Certify

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**  
Charles Avenue, Burgess Hill, West Sussex RH15 9UF

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

**ID3000, ID3002, ID3004, ID3006, ID3008, ID<sup>2</sup>net NGU,  
ID50, ID60, ID61, ID62, NFS2-8 2 Zone, NFS2-8 4 Zone, NFS2-8 8 Zone,  
ID2000, ID2002 and Pearl –  
Control and indicating equipment**

which have complied with the requirements of the following:

**EN 54-2: 1997 + A1: 2006  
EN 54-4: 1997 + A1: 2002 + A2: 2006**

**Certificate No: 154g**

**Issue Number: 08**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

<b>Certified Products</b>	<b>LPCB Ref. No.</b>
ID3000      Basic Equipment Kit, (BEK): Modular analogue addressable control and indicating equipment 020-538      Basic Equipment Kit ID3000, Group 0 020-538-001      ID3000 Basic Equipment Kit, Group 1 020-538-003      ID3000 Basic Equipment Kit, Group 3 020-538-004      ID3000 Basic Equipment Kit, Group 4 020-538-005      ID3000 Basic Equipment Kit, Group 5	154g/01
ID3002      Fixed build 2 loop analogue addressable control and indicating equipment 002-473      ID3002, 2 Loop, PSU3A, Group 0, Red 002-474      ID3002, 2 Loop, PSU3A, Group 0 002-474-001      ID3002, 2 Loop, PSU3A, Group 1 002-474-003      ID3002, 2 Loop, PSU3A, Group 3 002-474-004      ID3002, 2 Loop, PSU3A, Group 4 002-474-005      ID3002, 2 Loop, PSU3A, Group 5	154g/01
ID3004      Fixed build 4 loop analogue addressable control and indicating equipment 020-727      ID3004, 4 Loop, PSU7A, Group 0, LIB 020-728      ID3004, 4 Loop, PSU7A, Group 0, ELIB 020-729      ID3004, 4 Loop, PSU7A, Group 0, LIB, printer 020-730      ID3004, 4 Loop, PSU7A, Group 0, LIB, 64 zone LED	154g/01

*Continued...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 2 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

<b>Certified Products</b>	<b>LPCB Ref. No.</b>
ID3006	154g/01
Fixed build 6 loop analogue addressable control and indicating equipment	
020-731	ID3006, 6 Loop, PSU7A, Group 0, 2xLIB
020-732	ID3006, 6 Loop, PSU7A, Group 0, 2xELIB
020-733	ID3006, 6 Loop, PSU7A, Group 0, 2xLIB, printer
020-734	ID3006, 6 Loop, PSU7A, Group 0, 2xLIB, 64 zone LED
ID3008	154g/01
Fixed build 8 loop analogue addressable control and indicating equipment	
020-735	ID3008, 8 Loop, PSU7A, Group 0, 3xLIB, 78Ah Battery Enclosure
020-736	ID3008, 8 Loop, PSU7A, Group 0, 3xELIB, 78Ah Battery Enclosure
020-737	ID3008, 8 Loop, PSU7A, Group 0, 3xLIB, 78Ah Battery Enclosure, Printer
020-738	ID3008, 8 Loop, PSU7A, Group 0, 3xLIB, 78Ah Battery enclosure, printer, 64 Zone LED
Incorporating the following as modular units:	
Enclosures:	
020-472-009	Backbox Kit Standard, Black / Grey
020-473-009	Backbox Kit Extended, Black / Grey
020-474-009	Backbox Kit Extended Deep, Black / Grey
020-475-009	Backbox Kit Double Extended, Black / Grey
020-476-009	Backbox Kit Double Extended Deep, Black / Grey
020-480-009	Cover Kit Main Moulded, Black / Grey
020-481-009	Cover Kit Extended Moulded, Black / Grey

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 3 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### Certified Products

### LPCB Ref. No.

020-508-009	Backbox Extension Standard Assembly Black / Grey
020-509-009	Backbox Extension Deep Assembly Black / Grey
020-513-009	High Security Cover Kit Main, Black / Grey
020-514-009	High Security Cover Kit Extension
020-576	Main Cover, Stainless Steel
020-577	Extension Cover Stainless Steel
020-621-256	Zone Extension Cover, Stainless / Steel
020-621-009	256 Zone Extension Cover, Black / Grey
020-541-009	PSU7A / 78Ah Battery Enclosure
Modules:	
020-559-001	Zone Extension Chassis Kit 1-64 Zone C/W Display Module
020-559-002	Zone Extension Chassis Kit 65-128 Zone C/W Display Module
020-612	Double Extended Chassis Kit 256 Zone
020-708-009	Extension Chassis with Printer
020-644-009	Printer Assembly
020-588	Notifier Dual Loop Interface Board, (LIB)
020-549	Notifier Dual Enhanced Loop Interface Board, (ELIB)
020-478	RS232 Interface
020-479	RS485 Interface
020-648	PSU3A
020-579	PSU7A, (Requires Dual Transmission Path / Booster, PSU Interface)
020-548	PSU7A Status Indication
020-543	Dual Transmission Path / Booster, PSU Interface

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 4 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### Certified Products

LPCB Ref. No.

020-773	Routing Termination Unit (DEOL)
020-877	Extinguishing Interface Module M221-SI
020-643	ID <sup>2</sup> net Fibre Optic Interface Kit
020-647	ID <sup>2</sup> net Network Gateway Module, (NGM) for use in ID3000 Panel

Note 1: Products are available in language variants as follows:  
Group 0: English and Icelandic, with English manuals  
Group 1: English, Spanish, Portuguese, Icelandic and Italian  
Group 3: English, Swedish, Danish, Norwegian and Finish  
Group 4: English and Polish  
Group 5: English and Cyrillic

Note 2: Fixed build products incorporate a corresponding Basic Equipment Kit.

002-467	ID <sup>2</sup> net Network Gateway Unit, (NGU) Notifier Protocol	154g/N01
	Incorporating the following as modular units:	
020-643	ID <sup>2</sup> net Fibre Optic Interface Kit	
020-647	ID <sup>2</sup> net Network Gateway Module, (NGM) for use in ID3000 Panels	
020-648	PSU3A	

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 5 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### Certified Products

LPCB Ref. No.

Certified with the following options with requirements:

7.8	Output to fire alarm devices
7.9.1	Output to fire alarm routing equipment
7.9.2	Alarm confirmation input from fire alarm routing equipment
7.10.1	Output to fire protection equipment type A
7.10.3	Output to fire protection equipment type C
7.10.4	Fault monitoring of fire protection equipment
7.11	Delays to outputs
7.12.2	Dependency on more than one alarm signal type B
7.12.3	Dependency on more than one alarm signal type C
7.13	Alarm counter
8.3	Fault signals from points
8.9	Output to fault warning routing equipment
9.5	Disabling of addressable points
10	Test condition

ID50	Single loop analogue addressable control and indicating equipment	154g/02
002-455	ID50 Panel Group 0	
002-455-001	ID50 Panel Group 1	
002-455-003	ID50 Panel Group 3	
002-455-004	ID50 Panel Group 4	
	May also incorporate the following optional modular unit:	
002-553	RS485 Communication Kit	

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 6 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

Certified Products	LPCB Ref. No.
ID60 Single loop analogue addressable control and indicating equipment 002-456 ID60 Panel Group 0 002-456-001 ID60 Panel Group 1 002-456-003 ID60 Panel Group 3 002-456-004 ID60 Panel Group 4 May also incorporate the following optional modular unit: 002-553 RS485 Communication Kit	154g/03
ID61 Single loop analogue addressable control and indicating equipment 002-463 ID61 Panel Group 0 002-463-001 ID61 Panel Group 1 002-463-004 ID61 Panel Group 4 002-485-001 ID61 Panel Group 1 (Red) Incorporating the following modular unit: 020-648 PSU3A Kit May also incorporate the following optional modular units: 020-479 RS485 Communication Kit 020-644-009 Printer Kit	154g/04
ID62 Single loop analogue addressable control and indicating equipment 002-461 ID62 Panel Group 0 002-461-001 ID62 Panel Group 1 002-461-004 ID62 Panel Group 4 Incorporating the following modular unit: 020-648 PSU3A Kit	154g/05

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 7 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### Certified Products

LPCB Ref. No.

May also incorporate the following optional modular units:

020-479 RS485 Communication Kit  
020-644-009 Printer Kit

Certified with the following options with requirements:

7.8 Output to fire alarm devices  
7.9.1 Output to fire alarm routing equipment  
7.9.2 Alarm confirmation input from fire alarm routing equipment  
7.10.1 Outputs to fire protection equipment: Type A  
7.10.3 Outputs to fire protection equipment: Type C  
7.10.4 Fault monitoring of fire protection equipment  
7.11 Delays to Outputs  
7.12.2 Dependencies on more than one alarm signal: Type B  
7.13 Alarm counter  
8.3 Fault signals from points  
8.9 Output to fault warning routing equipment  
9.5 Disablement of addressable points  
10 Test condition

Note: Products are available in various language groups as follows:  
Group 0: English, Icelandic, French, Italian, Portuguese and Spanish, (shipped with English manuals)  
Group 1: English, Icelandic, French, Italian, Portuguese and Spanish  
Group 2: English, Dutch, German, French and Italian  
Group 3: English, Swedish, Danish, Norwegian and Finnish  
Group 4: English and Polish

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 8 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.



# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

*Continued ...*

### Certified Products

### LPCB Ref. No.

NFS2-8 2-8 zone conventional control and indicating equipment

NFS2-8 2 Zone

154g/06

002-477-122	Language region 1, light grey
002-477-129	Language region 1, black & grey
002-477-222	Language region 2, light grey
002-477-229	Language region 2, black & grey
002-477-322	Language region 3, light grey, dual relay
002-477-329	Language region 3, black & grey, dual relay, English manual
002-490-129	Language region 1, black & grey, dual relay, English manual
002-490-229	Language region 2, black & grey, dual relay, English manual
002-490-222	Language region 2, light grey, English manual

NFS2-8 4 Zone

154g/07

002-477-142	Language region 1, light grey
002-477-149	Language region 1, black & grey
002-477-242	Language region 2, light grey
002-477-249	Language region 2, black & grey
002-477-342	Language region 3, light grey, dual relay
002-477-349	Language region 3, black & grey, dual relay
002-490-149	Language region 1, black & grey, dual relay, English manual
002-490-249	Language region 2, black & grey, dual relay, English manual
002-490-242	Language region 2, light grey, English manual

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 9 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### Certified Products

LPCB Ref. No.

154g/08

NFS2-8 8 Zone

002-477-182	Language region 1, light grey
002-477-189	Language region 1, black & grey
002-477-282	Language region 2, light grey
002-477-289	Language region 2, black & grey
002-477-382	Language region 3, light grey, dual relay
002-477-389	Language region 3, black & grey, dual relay
002-490-189	Language region 1, black & grey, dual relay, English manual
002-490-289	Language region 2, black & grey, dual relay, English manual
002-490-282	Language region 2, light grey, English manual

Incorporating the following units:

020-747	8-Way relay kit
020-772	4-way monitored sounder kit

Certified with the following options from EN 54 Part 2:

7.8	Output to fire alarm devices
7.9.1	Output to fire alarm routing equipment
7.9.2	Alarm confirmation input from fire alarm routing equipment
7.10.1	Output to automatic fire protection equipment: Type A
7.10.3	Output to automatic fire protection equipment: Type C
7.10.4	Fault monitoring of fire protection equipment
7.11.1	Delays to outputs
7.11.2	Manual or automatic switching of delays to outputs
7.12.2	Dependency on more than one alarm signal: Type B
8.9	Output to fault warning routing equipment
10	Test condition

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 10 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

Certified Products	LPCB Ref. No.
Note 1: fixed build products incorporate a corresponding Basic equipment Kit.	
ID2000	154g/09
Basic Equipment Kit, (BEK): Modular analogue addressable control and indicating equipment.	
020-628	Basic equipment kit ID2000 Group 0,
020-628-001	Basic equipment kit ID2000 Group 1, UK ES PT IT
020-628-002	Basic equipment kit ID2000 Group 2, UK NL FR
ID2002:	154g/09
Fixed build 2 loop analogue addressable control and indicating equipment.	
002-459	ID2002, 2 loop control and indicating equipment, Group 1
Incorporating the following as optional modular units:	
Enclosures:	
020-472-009	Backbox Kit Standard, Black / Grey
020-473-009	Backbox Kit Extended, Black / Grey
020-474-009	Backbox Kit Extended Deep, Black / Grey
020-475-009	Backbox Kit Double Extended, Black / Grey
020-476-009	Backbox Kit Double Extended Deep, Black / Grey
020-480-009	Cover Kit Main Moulded, Black / Grey
020-481-009	Cover Kit Extended Moulded, Black / Grey
020-508-009	Backbox Extension Standard Assembly Black / Grey
020-509-009	Backbox Extension Deep Assembly Black / Grey
020-576	Main Cover, Stainless Steel
020-577	Extension Cover Stainless Steel
020-541-009	PSU7A / 78Ah Battery Enclosure

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 11 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

### Notifier by Honeywell (Pittway Systems Technology Group (Europe) Ltd)

#### Certified Products

LPCB Ref. No.

Modules:	
020-649-009	64 Zone Extension Chassis Kit 64 Zone C/W Display Module
020-708-009	Extension Chassis with Printer
020-644-009	Printer Assembly
020-588	Notifier Dual Loop Interface Board, (LIB)
020-478	RS232 Interface
020-479	RS485 Interface
020-648	PSU3A
020-579	PSU7A, (Requires Dual Transmission Path / Booster, PSU Interface)
020-543	Dual Transmission Path / Booster, PSU Interface
020-548	PSU7A Status Indication

Certified with the following options with requirements from EN 54 Part 2:

7.8	Output to fire alarm devices
7.9.1	Output to fire alarm routing equipment
7.9.2	Alarm confirmation input from fire alarm routing equipment
7.11	Delays to outputs
7.12.3	Dependency on more than one alarm signal type C
7.13	Alarm counter
8.3	Fault signals from points
9.5	Disablements of addressable points
10	Test condition

Note 2: Products are available in language variants as follows:

Group 0: English, Spanish, Portuguese and Italian (shipped with English manuals)

Group 1: English, Spanish, Portuguese and Italian

Group 2: English, Dutch, and French

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 12 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

Products		LPCB Ref. No.
Pearl	Two loop analogue addressable control and indicating equipment	154g/10

Incorporating the following units:

772489-NE	CPU board
124-408	3A PSU board
124-412	Network gateway module
124-421	Base board incorporating two loops
124-422	Display board
124-423	VdS I/O Module
124-426	Communications module
PRL-Box	Extended Back box

Incorporating the following optional regional language text inserts:

PRL-LED-EN	(English)
PRL-D	(German)
PRL-IB	(Iberia)
PRL-BNL	(Benelux)
PRL-LCD-NRD	(Swedish)
PRL-MEA	(Middle East and Africa)
PRL-IT	(Italian)

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 13 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### Certified Products

LPCB Ref. No.

Certified with the following options with requirements from EN 54-2:

- 7.8 Output to fire alarm devices
- 7.9.1 Output to fire alarm routing equipment
- 7.9.2 Alarm confirmation input from fire alarm routing equipment
- 7.10.1 Output to fire protection equipment type A
- 7.10.3 Output to fire protection equipment type C
- 7.10.4 Fault monitoring of fire protection equipment
- 7.11 Delays to outputs
- 7.12.2 Dependency on more than one alarm signal type B
- 7.12.3 Dependency on more than one alarm signal type C
- 7.13 Alarm counter
- 8.3 Fault signals from points
- 8.9 Output to fault warning routing equipment
- 9.5 Disablements of addressable points
- 10 Test condition

### Notes:

1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.
2. Scope of approval does not include the operation of the network functionality.

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 14 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

<b>Products</b>		<b>LPCB Ref. No.</b>
Pearl	Single loop analogue addressable control and indicating equipment	154g/11

Incorporating the following units:

772489-NE	CPU board
124-408	3A PSU board
124-412	Network gateway module
124-421-001	Single loop base board incorporating one loop
124-422	Display board
124-423	VdS I/O Module
124-426	Communications module
PRL-Box	Extended Back box

Incorporating the following optional regional language text inserts:

PRL-LED-EN-1	(English)
PRL-D-1	(German)
PRL-IB-1	(Iberia)
PRL-BNL-1	(Benelux)
PRL-LCD-NRD-1	(Swedish)
PRL-MEA-1	(Middle East and Africa)
PRL-IT-1	(Italian)

*Continued ...*

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 15 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### Certified Products

LPCB Ref. No.

Certified with the following options with requirements from EN 54-2:

- 7.8 Output to fire alarm devices
- 7.9.1 Output to fire alarm routing equipment
- 7.9.2 Alarm confirmation input from fire alarm routing equipment
- 7.10.1 Output to fire protection equipment type A
- 7.10.3 Output to fire protection equipment type C
- 7.10.4 Fault monitoring of fire protection equipment
- 7.11 Delays to outputs
- 7.12.2 Dependency on more than one alarm signal type B
- 7.12.3 Dependency on more than one alarm signal type C
- 7.13 Alarm counter
- 8.3 Fault signals from points
- 8.9 Output to fault warning routing equipment
- 9.5 Disablements of addressable points
- 10 Test condition

### Notes:

- 3. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.
- 4. Scope of approval does not include the operation of the network functionality.

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 16 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.



# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### ALTERNATIVE MODEL NUMBERS AND LABELLING

LPCB Ref No.	Model No.	Alternative Model No.	Labelled	Distributor's Cert No.
154g/01	ID3000(BEK)	XLS80e	Honeywell Control Systems Ltd. <sup>(1)</sup>	154g-(cl-01)
		IFC3000A(BEK)	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
		IFC3000B(BEK)	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
154g/01	ID3002	XLS80e-2L	Honeywell Control Systems Ltd. <sup>(1)</sup>	154g-(cl-01)
		IFC3002A	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
		IFC3002B	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
154g/01	ID3004	XLS80e-4L	Honeywell Control Systems Ltd. <sup>(1)</sup>	154g-(cl-01)
		IFC3004A	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
		IFC3004B	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
154g/01	ID3006	XLS80e-6L	Honeywell Control Systems Ltd. <sup>(1)</sup>	154g-(cl-01)
		IFC3006A	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
		IFC3006B	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
154g/01	ID3008	XLS80e-8L	Honeywell Control Systems Ltd. <sup>(1)</sup>	154g-(cl-01)
		IFC3008A	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
		IFC3008B	Johnson Controls Systems <sup>(2)</sup>	154g-(cl-02)
154g/01	ID3000(BEK)	Mach 2.8 Basic Kit	Building Protection Systems <sup>(3)</sup>	154g-(cl-04)
154g/01	ID3002	Mach 2.8 2 loop	Building Protection Systems <sup>(3)</sup>	154g-(cl-04)
154g/01	ID3004	Mach 2.8 4 loop	Building Protection Systems <sup>(3)</sup>	154g-(cl-04)
154g/01	ID3006	Mach 2.8 6 loop	Building Protection Systems <sup>(3)</sup>	154g-(cl-04)
154g/01	ID3008	Mach 2.8 8 loop	Building Protection Systems <sup>(3)</sup>	154g-(cl-04)

Continued ...

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 17 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 154g

**Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)**

### ALTERNATIVE MODEL NUMBERS AND LABELLING

LPCB Ref No.	Model No.	Alternative Model No.	Labelled	Distributor's Cert No.
154g/N01	ID <sup>2</sup> net NGU	XLS80e-NI NGU IFC-2NetNGU	Honeywell Control Systems Ltd. <sup>(1)</sup> Johnson Controls Systems <sup>(2)</sup>	154g-(cl-01) 154g-(cl-02)
154g/06	NFS2-8 2 zone	Zircon 2 zone	Bardic by Honeywell <sup>(4)</sup>	154g-(cl-03)
154g/07	NFS2-8 4 zone	Zircon 4 zone	Bardic by Honeywell <sup>(4)</sup>	154g-(cl-03)
154g/08	NFS2-8 8 zone	Zircon 8 zone	Bardic by Honeywell <sup>(4)</sup>	154g-(cl-03)
154g/06	NFS2-8 2 zone	FLS2-8 2 zone	Firelite by Honeywell <sup>(5)</sup>	154g
154g/07	NFS2-8 4 zone	FLS2-8 4 zone	Firelite by Honeywell <sup>(5)</sup>	154g
154g/08	NFS2-8 8 zone	FLS2-8 8 Zone	Firelite by Honeywell <sup>(5)</sup>	154g

<sup>(1)</sup>Honeywell Control Systems Ltd

<sup>(2)</sup>Johnson Controls Systems and Service Serl

<sup>(3)</sup>Building Protection Systems (NI) Limited

<sup>(4)</sup>Bardic By Honeywell (Novar Systems Ltd)

<sup>(5)</sup>Firelite by Honey well (Pittway Systems Technology Group (Europe) Ltd)

For details of Cross-Listed products and alternative branding please see pages 17-18.

**Appendix Issue No: 08**

**Page: 18 of 18**

**Date of Issue: 02 January 2013**

**Signed for and on behalf of LPCB**

**E MATTIE-SULEIMAN**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.