

Life Safety Systems

Honeywell Life Safety Systems

UK & Ireland

Caburn House

Brooks Road

Lewes

East Sussex BN27 2BY

Tel: +44 (0)1273 897222

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011
N° 007 - CPR - 2013

1. *Unique Product identification code:*

ID, NF & Mach2.8 (EN54:2&4)

2. *Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):*

Two Loop Analogue Addressable Control and Indicating Panel	ID300(ID3002)
Two - Eight Loop Analogue Addressable Control and Indicating Panel	ID3000
Two Loop Analogue Addressable Control and Indicating GmBh Panel	NF300
Two - Eight Loop Analogue Addressable Control and Indicating GmBh Panel	NF3000
Two - Eight Loop Analogue Addressable Control and Indicating GmBh Panel (NF3000+NGM)	NF500
Two - Eight Loop Analogue Addressable Control and Indicating GmBh Panel (NF3000+NGM)	NF5000
Two - Eight Loop Analogue Addressable Control and Indicating (BPS) Panel	Mach2.8

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:*

Fire detection and fire alarm systems installed in buildings.

4. *Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):*

**Notifier by Honeywell
(Pittway Systems Technology Group Europe Ltd)
Manufactured by:
Honeywell Life Safety Systems
140 Waterside Road
Hamilton Industrial Estate
Leicester
LE5 1TN
UNITED KINGDOM**

5. *Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):*

Not Applicable

6. *System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:*

System 1

7. *In case of the declaration of performance concerning a construction product covered by a harmonized standard:*

VdS Schadenverhütung GmbH

performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

0786-CPD-20878

8. *In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:*

Not applicable, see item 7

9. Declared Performance:


All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below:

Essential characteristics	Performance	Harmonized Technical Specification	
		EN 54-2: 1997 + A1: 2006	EN 54-4: 1997 + A2: 2006
Operational reliability	Pass	Art.: 4, 5, 6, 7, 8, 9, 10,12, 13, 14	Art.: 4, 5, 6, 7, 8
Durability of operational reliability Temperature resistance	Pass	Art.: 15.4	Art.: 9.5
Durability of operational reliability Vibration resistance	Pass	Art.: 15.6, 15.7, 15.15	Art.: 9.7, 9.8, 9.15
Durability of operational reliability Electrical stability	Pass	Art.: 15.8 to 15.13	Art.: 9.9 to 9.13
Durability of operational reliability Humidity resistance	Pass	Art.: 15.5, 15.14	Art.: 9.6, 9.14
Performance under fire conditions	Pass	Art.: 4, 5, 7	
Response delay (response time to fire)	Pass	Art.: 7.1, 7.7, 7.11, 7.12	
Performance of power supply	Pass		Art.: 4, 5, 6
Operational Reliability	NPD	Art.: 11	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:

Name and Function..... MARK ALTON M.D.

Signature: 

Date: 8th July 2013